



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor



800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

January 31, 2024

Steve Wabschall
Reeder Beach Resort
Via email: wabschall@hotmail.com

**Re: Centralized Arsenic Treatment (PR#62-2023)
Reeder Beach Resort (PWS ID#91951)
Final Approval**

Dear Steve:

On August 30, 2023, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the July 6, 2023 conditional approval letter.

Final approval is issued at this time, and the facility is approved for use. Note that arsenic sampling reduces to quarterly monitoring for one year, at which time (depending on results), you can request a monitoring reduction to annually.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Jenifer George Parish, REHS, Multnomah County Health Department