

December 17, 2025

George Youngberg
Youngberg Pump & Well Drilling
37008 SE Kemp Rd
Estacada, OR 97023

**Re: Poly Storage Tank (PR#152-2025)
Eagle Creek Saloon (PWS ID#93548)
Conditional Approval**

Dear George:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Poly Storage Tank for Eagle Creek Saloon. On December 8, 2025, our office received pictures of the existing tank and well building and, on December 11, 2025, a project description. A plan review fee of \$825 was received on December 8, 2025.

The project includes a 5000 gallon Norwesco polyethylene storage tank that was previously installed at Eagle Creek Saloon.

The plans are approved subject to the following conditions:

- The current vent is mounted with the opening positioned horizontally. The vent opening must be downward facing to prevent rainwater intrusion. This could simply be an elbow installed on the end of the current vent or a similar solution.

Until we receive verification that the conditions have been met and final approval has been issued, the storage tank is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #152-2025 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Joel Ferguson, REHS, Clackamas County Health Department
Megan Freauff, Eagle Creek Saloon