



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: 971-673-0405
Fax: 503-673-0694
www.healthoregon.org/dws

November 28, 2023

David Jacob, PE
Hydra Engineering
PO Box 327
Rhododendron, OR 97049

Sent by email only

**Re: Filtration Plant Upgrades (PR#152-2022)
Minikahda Water System (PWS ID#93609)
Final Approval**

Dear David:

On September 18, 2023, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the October 17, 2022 conditional approval letter.

The Harmsco HC/40-LT2 filters in Harmsco Hurricane Muni 40 mp housing are granted 2.5 log removal credit for *Giardia lamblia* and 2.0 log removal credit for *Cryptosporidium*.

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at 503-939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,

Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Carrie Gentry, PE, OHA/DWS