



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

750 SE Emigrant Ave., Suite 150
Pendleton, OR 97801
(541) 276-8006
FAX (541) 276-4778
www.healthoregon.org/dwp

August 23, 2023

Jeff Painter
Lindsay Ecowater
2452 SW 4th Avenue
Ontario, Oregon 97914

**Re: Chlorination System, Plan Review #161-2022, Country Campground, PWS ID #4193641
Final Approval**

Dear Jeff:

Thank you for your submittal of plan review information to the Oregon Health Authority's Drinking Water Services (DWS). On November 2, 2022, our office received photos that were marked to show where the equipment will be installed, and specifications for the feed pump and solution tank. The plan review fee of \$248 was received on November 5, 2022. The project consisted of installing a hypochlorination system with a 30 GPD Stenner model E20PHH feed pump, a Stenner solution tank, and related appurtenances. Final approval is granted for the project.

I note that photos of the installation were provided by Verna Pike on January 17, 2023, and a chlorine residual was measured and recorded for the July 19, 2023 coliform samples.

If you have any questions or would like this in an alternate format, please feel free to email me at william.h.goss@oha.oregon.gov or call me at (541) 966-0900.

Sincerely,

William Goss, P.E.
Regional Engineer

c: Julie Wray, OHA–DWS, Portland, OR
Verna Pike, Country Campground
Eric Evans, REHS, Malheur County (pdf copy only)
Evan Magner, REHST, Malheur County (pdf copy only)