



May 9, 2024

800 NE Oregon Street, Suite 640 Portland, OR 97232-2162 Phone: 971-673-0405 Fax: 503-673-0694

www.healthoregon.org/dws

Daniel Reitz (pumpvp@gmail.com)
Lost Valley Educational Center
81868 Lost Valley Lane
Dexter, OR 97431

Sent by email only.

Re: Arsenic Treatment (PR#56-2023)

Lost Valley Educational Center (PWS ID#94011)

Final Approval

## Dear Daniel:

On May 8, 2024 our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the April 20, 2023 conditional approval letter.

The project includes the installation of an arsenic treatment system involving water softeners using Purolite A330 anion resin for pH reduction and Adedge AD33 iron oxide media adsorption filters in the existing pump house.

In addition to the final approval, I have the following comments:

- Arsenic monitoring will be once every calendar quarter. Monitoring may be reduced to one sample per year after monitoring results are below the MCL for arsenic for at least four consecutive calendar quarters. Monitoring may not be reduced to less frequently than once per year.
- Any waste media must be disposed of in a method acceptable by the Department of Environmental Quality.

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at 503-939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,

Keith Male, PE Regional Engineer Drinking Water Services

cc: Julie Wray, DWS

Nicholas Alviani, Lane County Health Department