



PUBLIC HEALTH DIVISION  
Drinking Water Services

Tina Kotek, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-201-9794  
Fax: 971-673-0694  
[www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

July 7, 2023

Daryl Hensley  
Water/Wastewater Supervisor  
Brucepac  
Via email: [DHensley@brucepac.com](mailto:DHensley@brucepac.com)

**Re: Well #7 (PR#10-2023)  
JLR (PWS ID#94431)  
Final Approval**

Dear Daryl:

On June 9, 2023, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the April 17, 2023 conditional approval letter. The remaining item, a coliform sample result, was provided on July 5, 2023.

The sample results submitted in June included an arsenic sample result over the maximum contaminant level. However, the water system treats for arsenic.

Final approval is issued at this time, and the facility is approved for use. Note that with the addition of any new source of water, the lead and copper monitoring sampling returns to a six-month schedule for at least two rounds.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

cc: Joshua Teamus, REHS, Oregon Department of Agriculture