

Tina Kotek, Governor

January 13, 2026

Andy Hoover, PE
Lamb Weston
8701 W. Gage Blvd.
Kennewick, Washington 99336

**Re: New 5000-Gallon Reservoir, Plan Review #157-2025, Lamb Weston,
PWS ID #4194562
Conditional Approval**

Dear Andy:

Thank you for your submittal of plan review information to the Oregon Health Authority's Drinking Water Services (DWS). On December 23, 2025, a set of drawings and specifications for the reservoir were received. On December 29, 2025, the plan review fee of \$825 was received. I note that a Land Use Compatibility Statement is not required for this project. The project consists of installing a new 5000-gallon Norwesco polyethylene reservoir along with related piping and appurtenances. The plans have been reviewed and are approved based on meeting the following conditions:

- The downturned roof vent shown in the drawing must be screened to prevent animal and insect intrusion.
- The overflow piping outlet must have a flap valve, screening, or other provision to prevent animal and insect intrusion.
- The new chemical feed pumps must be certified to NSF Standard 61 or equivalent.
- After installation the reservoir must be disinfected and a bacteria sample collected. See [OAR 333-061-0050\(10\)](#).

Upon completion of the project, please verify in writing that the construction was completed according to the submitted plans. Until Final Approval is granted for the project, the new facilities are not approved for use.

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at william.h.goss@oha.oregon.gov .

Sincerely,



William Goss, PE
Regional Engineer

c: Julie Wray, OHA-DWS

 Melissa Ney, REHS, Oregon Dept. of Agriculture (pdf copy only)

 Jared Miller, Lamb Weston (pdf copy only)

