



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/DWP

July 18, 2024

Maureen Hennenfent, EI
Project Engineer
Keller Associates

Re: **Brooks-Hopmere Master Plan (PR#93-2024)**
Brooks CSD (PWS ID#94699)
Concurrence with Master Plan

Dear Maureen:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Brooks-Hopmere Water System Master Plan for Brooks CSD. On July 3, 2024, our office received a copy of the plan. A plan review fee of \$825 was also received.

The Master Plan represents a 20-year planning horizon out to the year 2044. The plan includes a system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and a list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan is required and was included. Upon review of the Master Plan, it appears the elements listed in Oregon Administrative Rules (OAR) 333-061-0060(5) have been addressed.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Chantal Wikstrom, REHS, OHA/DWS
Greg DeBlase, REHS, Marion County Health Department
Peter Olsen, PE, Keller Associates
Chris Einmo, ceinmo@co.marion.or.us
Tsigereda Woldegiorgis, TWoldegiorgis@co.marion.or.us