

February 18, 2026

Stoner Bell, PE  
Bell Design Co.  
PO Box 308  
Bingen, Washington 98605

**Re: Two New Reservoirs and Chlorination System, Plan Review #153-2025,  
Chemical Waste Mgt. of NW Inc., PWS ID #4194718  
Final Approval**

Dear Mr. Bell:

Thank you for your submittal of record drawings for the project and the required statement to the Oregon Health Authority's Drinking Water Services (DWS). The project consisted of installing two new 15,500-gallon Norwesco HDPE storage tanks, related piping, appurtenances, and a hypochlorination system. Final approval is granted for the project.

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at [william.h.goss@oha.oregon.gov](mailto:william.h.goss@oha.oregon.gov).

Sincerely,



William Goss, PE  
Regional Engineer

c: Julie Wray, OHA-DWS

Greg Pincelli, PE, Chemical Waste Management of NW Inc. (pdf copy only)