

2 April 2025

Todd Hafner  
Church on the Hill  
2707 Maranatha Court SE  
Turner Oregon 97392

*sent via email only*

**Re: Storage Tank – 1,000 gal (PR #38-2025)  
Church on the Hill (WS ID #94911)  
Conditional Approval**

Dear Mr. Hafner:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the reservoir installed around 2020 for Church on the Hill. On 19 March 2025 our office received a plan review fee of \$825. Shortly after, we spoke about the details of the storage tank that are described in the recent water system survey from last summer.

The project includes a 1,000-gallon underground polymer storage tank.

The plans are approved subject to the following conditions:

*{ unless otherwise noted, rule references are from OAR 333-061-0050(6) }*

- A fence or other vandal deterrent must protect the reservoir (a)(P)
- A screened, down-turned vent must protect the reservoir (a)(L)
- If a drain exists, it must be protected with a flap-valve, or otherwise (a)(M)
- All items in contact with potable water must meet NSF Standard 61 333-061-0087(5)

**Until we receive verification that the conditions have been met and final approval has been issued, the reservoir is not approved for use.** Documentation demonstrating how the above conditions were met should reference Plan Review #38-2025 and can be emailed to me at [peter.r.farrelly@oregon.oha.gov](mailto:peter.r.farrelly@oregon.oha.gov)

If you have any questions, please feel free to email me or call me at 971.201.6428.

Sincerely,

A handwritten signature in black ink, appearing to read "Pete Farrelly", is placed over a light blue rectangular background.

Pete Farrelly, PE  
Regional Engineer  
Drinking Water Services

cc: Greg DeBlase, Marion County