

May 7, 2025

Doug Rouse
Camp Remote
54147 Sandy Creek Road
Myrtle Point, OR 97458

**Re: Water Storage Tanks (PR# 2025-21)
Camp Remote (PWS ID# 94995)
Conditional Approval**

Dear Doug:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the water storage tanks for Camp Remote. On February 3, 2025, our office received photos of the water storage tanks and manifolds, a plan review fee of \$825 was paid on February 4, 2025.

The project includes installation of three 2,500-gallon Norwesco water storage tanks.

The plans are approved subject to the following conditions:

- All items in contact with potable water must meet NSF Standard 61, or equivalent. Provide additional information on pipe material and fittings used on storage tank inlet and outlet manifolds.
- Where the only access manhole is located on the roof, a removable ladder must be available.

In addition to the above conditions, I have the following recommendation:

- Install a pressure transducer, float gauge, or another means of determining water level in the storage tanks.

Until we receive verification that the conditions have been met and final approval has been issued, the water storage tanks are not approved for use. Documentation demonstrating how the above conditions were met should reference Plan Review #2025-21

and can be emailed to me at baxter.call@oha.oregon.gov.

If you have any questions, please feel free to email me or call me at 541-393-4374.

Sincerely,



Baxter Call, PE
Regional Engineer
Drinking Water Services

CC: Julie Wray, DWS
Jeff Stoddard, Camp Remote Caretaker
Rick Hallmark, Coos Health and Wellness

