

Tina Kotek, Governor

April 8th, 2026

Jonathan Woody
Diamond Lake Gas Station
3641 Glenbrook Loop Road
Riddle, OR 97469

sent by email only


**Re: Surface Water Treatment (PR#108-2025)
Diamond Lake Gas Station (PWS ID#95243)
Final Approval**

Dear Jonathan Woody:

On March 23rd, 2026, the Oregon Health Authority Drinking Water Services (DWS) received confirmation that the above project was completed according to the plans submitted and conditions set forth in the December 9th, 2025 conditional approval letter and as-builts reviewed by i.e. Engineering.

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. The selected Harmsco housing/cartridge combination is accredited with a log removal credit of 2.0 for Cryptosporidium, 2.5 log removal credit for Giardia and zero log removal credit for viruses. The selected Viqua Pro24-186 Ultraviolet Reactor is accredited with 5.5+ Cryptosporidium inactivation, 5.5+ Giardia inactivation and 4.0 viral inactivation. The chlorine injection system has been installed for maintaining a disinfecting residual in the distribution system and has not been accredited inactivation credit. Please review the water system's online data profile for the most current sampling requirements and updates. If you have any questions, please feel free to call me at 541-231-9077.

Sincerely,



Zach Golik, PE
Regional Engineer
OHA-Drinking Water Services