

March 19, 2026

Andrew Brown  
J&J Snack Foods  
103 Depot Street  
Weston, Oregon 97886

**Re: Chlorination System, Plan Review #56-2021, JJ Snack Food Handheld,  
PWS ID #4195569  
Final Approval**

Dear Mr. Brown:

Thank you for sending photos that confirm the Chem-Tainer chlorine solution tanks were replaced with Poly Processing brand ones that have NSF Standard 61 certification. The project consisted of installing an Evoqua OSEC L on-site hypochlorite generation system, ProMinent Gamma/X metering pumps, a Pentair/Fleck 9100 SXT water softener, and tanks for the salt brine and hypochlorite solution storage. Final approval is granted for the project. If you have any questions or would like this in an alternate format, please feel free to email me at [william.h.goss@oha.oregon.gov](mailto:william.h.goss@oha.oregon.gov) or call me at (541) 966-0900.

Sincerely,



William Goss, P.E.  
Regional Engineer

c: Julie Wray, OHA-DWS, Portland, OR

Melissa Ney, REHS, Oregon Dept. of Agriculture (pdf copy only)

Daniel Ramon, J&J Snack Food (pdf copy only)

Martin Hubert, J&J Snack Food (pdf copy only)

Michael Watts, J&J Snack Food (pdf copy only)

Sandra Stewart, J&J Snack Food (pdf copy only)

Scott Buettner, J&J Snack Food (pdf copy only)