



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

March 2, 2023

Sergio Hernandez
Facilities & Bottling Supervisor
Adelsheim Vineyards
Via email: shernandez@adelsheimvineyard.com

**Re: 15,000-gallon storage tank (PR#8-2023)
Adelsheim Vineyards (PWS ID#95668)
Final Approval**

Dear Sergio:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the storage tank for Adelsheim Vineyards. On January 17, 2023, our office received as-built drawings, NSF certification and a plan review fee of \$825.

The project includes a 15,000-gallon Xerxes storage tank, installed in 2022. After review of the submitted documents and Oregon Department of Agriculture's 2022 survey document, the tank appears to meet construction standards. Post construction sampling for coliform is not required, as the tank is already in use.

Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Sarah Schwab, REHS, Oregon Department of Agriculture
Nicole Alfafara, REHS, OHA/DWS
Gina Hennen, Adelsheim Vineyards, ghennen@adelsheim.com