

August 22, 2022



800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794 Fax: 971-673-0694 www.healthoregon.org/dwp

Pete Munoz, PE Biohabitats, Inc Via email: P.Munoz@biohabitats.com

Re: New Water System, Water Treatment and Storage (PR#102-2020) PAE Living Building (PWS ID# 95690) Final Approval

Dear Pete:

On June 13, 2022, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the December 9, 2020 conditional approval letter. Filter-to-waste data was received on June 17th and August 8th, showing the initial operation of the filters.

Final approval is issued at this time, and the facility is approved for use.

Note that a Water Treatment 1 operator is needed for this system. Our certification unit will reach out with a formal letter via email noting that the system will need to provide DWS with the operator information.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE Regional Engineer Drinking Water Services

ec: Carolyn Clemons, OHA/DWS