



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: 971-673-0405
Fax: 503-673-0694
www.healthoregon.org/dws

July 30, 2024

Randy Duval
Mapleton School District
Via email: rduval@mapleton.k12.or.us

**Re: New System and Well (PR #26-2023)
Mapleton School District (PWS ID #95707)
Final Approval**

Dear Randy:

On April 29, 2024, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the May 10, 2023 conditional approval letter. Coliform and chemical sampling (IOC, SOC, VOC, nitrate, nitrite, and arsenic) results from the new well (Well ID Lane 78976) were submitted on May 9 and June 13, 2024, respectively.

It is noted that the Canature 95 MTS water softener system is NSF/ANSI 44 certified for residential water applications. Drinking Water Services (DWS) approves this equipment for use by the PWS at this time. If, in the future, the water softening system does not meet the performance and finished water quality requirements of the PWS, an upgrade to a NSF/ANSI 53 or 61 certified water softening system may be required.

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at 541-393-4374.

Sincerely,

Baxter Call, PE
Regional Engineer
Drinking Water Services

cc: File, DWS Portland
Amy Bleekman, REHS, OHA/DWS
Nicholas Alviani, REHS, Lane County Environmental Health