



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

750 SE Emigrant Ave., Suite 150
Pendleton, OR 97801
(541) 276-8006
FAX (541) 276-4778
www.healthoregon.org/dwp

May 31, 2024

Ben Haws, PE
J-U-B Engineers, Inc.
3611 S. Zintel Way
Kennewick, Washington 99337

**Re: New Well, Plan Review #97-2023, Project PATH Water System, PWS ID #4195716
Final Approval**

Dear Ben:

An on-site inspection conducted on May 2, 2024, confirmed that the well, pressure tank, and related appurtenances were installed according to the approved plans and meet Drinking Water Services' construction standards. **Final approval is granted for the project.**

I note the following:

- A pressure switch was installed to control the well pump instead of a variable frequency drive.
- A hypochlorination system was installed to provide a chlorine residual in the water.

If you have any questions, please feel free to e-mail me at william.h.goss@oha.oregon.gov or call at 541-966-0900.

Sincerely,

William Goss, P.E.
Regional Engineer

c: Julie Wray, OHA-DWS, Portland
Leon Scheel, City of Umatilla (pdf copy only)
Scott Coleman, City of Umatilla (pdf copy only)
Andres Romero, PE, JUB Engineers, Inc. (pdf copy only)