



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

November 16, 2023

Amber Sagnotti
Jachter Family Wines
Via email: asagnotti@jachterwine.com

**Re: New System and Well (PR#112-2023)
Jachter Family Wines (PWS ID# 95725)
Final Approval**

Dear Amber:

On November 13, 2023, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the September 18, 2023 conditional approval letter, with the exception of the overflow and vents for the two buried 2,500-gallon tanks. The water system acknowledged the risk of not having vents or overflows on these two tanks.

Final approval is issued at this time, and the facility is approved for use. If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Sarah Schwab, REHS, Oregon Department of Agriculture