





750 SE Emigrant Ave., Suite 150 Pendleton, OR 97801 (541) 276-8006 FAX (541) 276-4778 www.healthoregon.org/dwp

Aryan Nijjar Super 7 Mini-Mart 36 Eagle Crest Drive Union Gap, Washington 98903

Re: New Well, Plan Review #59-2024, Super 7 Mini-Mart, PWS ID #4195739 Final Approval

Dear Aryan:

An on-site inspection conducted on September 26, 2024, confirmed that the well, pressure tank, and related appurtenances were installed according to the approved plans and meet Drinking Water Services' construction standards. **Final approval is granted for the project and the well L153236 may be placed into service.**

I have the following comments:

- I recommend the sample tap next to the pressure tank be replumbed higher off the floor so water can be run into a bucket and make sample collection easier.
- Sample results for coliform bacteria, nitrate and arsenic that met water quality standards were received.
- I note that Baggett Lane is within the 100-foot setback area for the well. The waiver request is approved as the confined aquifer is protected against contamination from surface runoff or hazardous liquids that may be spilled in the vicinity, and unauthorized access is discouraged by having the well covered.

If you have any questions, please feel free to e-mail me at <u>william.h.goss@oha.oregon.gov</u> or call at 541-966-0900.

Sincerely,

William How

William Goss, P.E. Regional Engineer

c: Julie Wray, OHA-DWS, Portland Melissa Ney, REHS, Oregon Dept. of Agriculture (pdf copy only) Tommy Laird, Oregon Water Resources Department (pdf copy only) Christopher Prewitt