

Tina Kotek, Governor

March 5, 2026

Paul Snegirev  
Boones Ferry Berry Farm  
Via email: [customplanting@yahoo.com](mailto:customplanting@yahoo.com)

**Re: New System and Well (PR#73-2022)  
Boones Ferry Berry Farm (PWS ID#95749)  
Final Approval**

Dear Paul:

Thank you for submitting additional information for the well for Boones Ferry Berry Farm. A regional geologist reviewed the details of the below-ground construction of the well (Well ID MARI 70439) and noted that the well is properly constructed in a confined aquifer with low sensitivity. A waiver for the sanitary hazard within 100' of the well was approved. A link to this waiver is provided in the email that accompanies this letter.

A raw water coliform sample result was provided, and the Marion County Health Department provided above-ground details in their 2025 survey.

Final approval is issued at this time, and the facility is approved for use.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE  
Regional Engineer  
OHA-Drinking Water Services  
[Carrie.L.Gentry@oha.oregon.gov](mailto:Carrie.L.Gentry@oha.oregon.gov)

cc: Chantal Wikstrom, REHS, OHA/DWS  
Greg DeBlase, REHS, Marion County Health Department