

December

Bradley Vaughan
Faster Permits
Via email: bradley@fasterpermits.com

**Re: New System and South Well (PR#77-2024)
Two Capes Campground (PWS ID#95752)
Conditional Approval**

Dear Bradley:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of additional plan review information. The water system is planning on only connecting the South Well (Well ID TILL 53322) at this time. An application for a waiver from construction standards for the radius of control issue around the well. A link to the approved waiver will be included in the email that accompanies this letter.

In addition to the South Well, the project includes installation of a 50-gallon Flexcon flexlite FL-17, Custom Care water C43 water softener, Viqua Arros 22 UV system, and Harmsco HC/40-50 cartidge filter with HUR 40 HP filter housing.

The plans are approved with the following conditions:

- All items in contact with water must meet NSF Standard 61 or equivalent. This includes the Flexcon pressure tank.
- Bypass piping around the pressure tanks must be provided to permit operation of the system while a tank is being maintained or repaired (schematic or photo showing how this requirement is met would be acceptable).

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #77-2024 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
OHA-Drinking Water Services
Carrie.L.Gentry@oha.oregon.gov

cc: Nicole Alfafara, OHA/DWS
Jaime Craig, REHS, Tillamook County Health Department
Kevin Gindlesperger, kevingindy@yahoo.com