

**Application for Waiver from Construction Standards for Public Water Systems**

Water System Name	Portland Water Bureau	PWS ID	00657
Project or Facility	SE 166 <sup>th</sup> Pl & Haig	County	Multnomah
Need for waiver identified:	<input type="checkbox"/> Water System Survey	Date of Survey	
	<input type="checkbox"/> Plan Review # Exempt		

Construction standard requested to be waived: OAR 333-061-0050 (9)(b) water sewer separation

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. A new 6" DI water pipe will be installed for 482' in SE 166<sup>th</sup> Pl. A segment from 1+51 to 2+09 will only have 3.5' of horizontal separation from a parallel existing sanitary sewer.

Describe why meeting the standard is highly burdensome or impractical. The water alignment is needed for this short section due to an existing storm water system that prevents maintaining 5' of horizontal separation. The remaining sections of the new pipe will have 5' of horizontal separation per the standard, but cannot be done for this 58' segment due to existing utility conflict.

Describe proposed alternate measure that provide adequate protection to public health and safety. The proposed water pipe will be encased in CLSM for the segment that is within 5' of the existing sewer pipe.

_____	10-15-24
Signature	Date

Name Mac Gifford

<p>Attach plans of proposed waiver request or additional supporting information and</p> <ul style="list-style-type: none"> <li>• Email your regulator; or</li> <li>• Email <a href="mailto:dws.planreview@dhsosha.state.or.us">dws.planreview@dhsosha.state.or.us</a>; or</li> <li>• Mail: Oregon Health Authority Drinking Water Services #640 PO Box 14450</li> </ul>
---

Address 1900 N Interstate Ave  
City/State/Zip Portland, OR 97227  
Telephone Number 503-823-1507

Portland, OR 97293-0450

Comments:

Attachments: Improvement Plans for SE 166<sup>th</sup> Pl

**OHA Use Only**

Waiver ID 499-2024

Entered into waiver database

Plan Review Coordinator's notes: Proposed alternate measure appears to protect public health.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved      Comments:

Denied

*Kari Salis*

10/21/2024

Drinking Water Regional Manager Signature  
Oregon Health Authority

Date

Waiver database updated