

Application for Waiver from Construction Standards for Public Water Systems

Water System Name Portland Water Bureau

PWS ID 00657

Project or Facility NE 42nd Ave

County Multnomah

Need for waiver identified: ☐ Water System Survey

Date of Survey

☐ Plan Review # Exempt

Construction standard requested to be waived: OAR 333-061-0050 (9)(b) water sewer separation


As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. A 50' portion of water main is being relocated to accommodate a new sanitary sewer manhole. The proposed water pipe alignment will have 4'2" of parallel vertical separation from an existing sewer pipe, creating a Zone 2 conflict. See sheet 3 of the attached plans.

Describe why meeting the standard is highly burdensome or impractical. This is the most amount of distance that can be achieved from the existing sewer pipe while leaving enough room to construct the new sewer manhole.

Describe proposed alternate measure that provide adequate protection to public health and safety. The entire length of pipe that is in conflict with the existing sewer from 0+11B to 0+61B will be encased in CLSM.



Signature

2/26/2025

Date

Name Mac Gifford

Address 1900 N Interstate Ave

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:

Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

City/State/Zip Portland, OR 97227

Telephone Number 503-823-1507

☐ Comments:

☒ Attachments: Improvement Plans for NE 42nd Ave

OHA Use Only

Waiver ID 2025-523

Entered into waiver database ☒

☐ Plan Review Coordinator's notes: (Carrie is out, KS did sole review)

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

☒ Approved Comments: CLSM is an adequate alternate measure.

☐ Denied



2/27/2025

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated ☒