## Center for Health Protection, Drinking Water Services



## Application for Waiver from Construction Standards for Public Water Systems

Revised March 2025

| Water System Name: Portland Water Bureau         | PWS ID: 00657    |
|--|------------------|
| Project or Facility: NE Hassalo                  | County:Multnomah |
| Need for waiver identified:  Water System Survey | Date of Survey:  |
| ✓ Plan Review # Exempt                           |                  |

Construction standard requested to be waived: OAR 333-061-0050 (9)(b) water sewer separation

As provided under OAR 333-061-0055, OHA may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of OHA that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by OHA to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of OHA, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard.

A 600' water pipe will be relocated away from a parallel existing sanitary sewer, but the last 40' of the relocated water pipe must tie back into the existing Zone 2 conflict with only 2.5' of horizontal Describe why meeting the standard is highly burdensome or impractical.

The water pipe must tie into the existing system. Relocating the entire sewer is out of scope of this project.

Describe proposed alternate measure that provide adequate protection to public health and safety.

The 40' length of the proposed water pipe tie in will be encased in CLSM.

The 40' length of the proposed water pipe tie in will be encased in CLSM.

EMAIL this form along with plans of proposed waiver request and additional supporting information to your regulator or <a href="mailto:dws.planreview@odhsoha.oregon.gov">dws.planreview@odhsoha.oregon.gov</a>. If you are unable to send your documents electronically, please contact OHA before mailing them.

| Signature:        | Mac Sford | Date: 3/25/25      |
|-------------------|-----------|--------------------|
| Name: Mac Gifford | V // (    | continue to page 2 |

| Address: 1900 N Interstate Ave B320  |                                 |
|--|---------------------------------|
| City/State/Zip: Portland, OR 97227   |                                 |
| Phone Number: 503-823-1507   |                                 |
| Email Address: mac.gifford@portlandoregon.gov  |                                 |
| Comments:  |                                 |
|  |                                 |
|  |                                 |
| ✓ Attachments (describe):  |                                 |
| Improvement Plans for W02827 NE Hassalo  |                                 |
|  |                                 |
| OHA Use Only   |                                 |
| Waiver ID: 527-2025  |                                 |
| Entered into waiver database 🗹   |                                 |
| ✓ Plan Review Coordinator's notes: Proposed encasement with CLS the Zone 2 conflict.       | SM is an appropriate remedy for |
| After due consideration the above requested waiver from the constructi 061-0050 is hereby: | on standards of OAR 333-        |
| Approved Comments:   |                                 |
| Denied Denied  |                                 |
|  |                                 |
|  |                                 |
| Kari Salis   | 0/04/0005                       |
|  | 3/31/2025<br>Date               |
| OHA Drinking Water Services  | Duic                            |
| Waiver database updated X  |                                 |