

Application for Waiver from Construction Standards for Public Water Systems

Revised September 2025

Water System Name: Portland Water Bureau

PWS ID: 00657

Project or Facility: NE 136th PI

County: Multnomah

Need for waiver identified: ☐ Water System Survey

Date of Survey:

☐ Plan Review # Exempt

Construction standard requested to be waived: OAR 333-061-0050 (9)(b) water sewer separation

As provided under OAR 333-061-0055, OHA may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of OHA that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by OHA to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of OHA, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard (**Attach additional document, if necessary**).

The proposed 6" water line will only have 3'-5' of parallel horizontal separation from an existing sewer pipe between 4+99 to 5+19, creating a Zone 2 conflict.

Describe why meeting the standard is highly burdensome or impractical.


Conflict with the existing stormwater sump prevents making the water line jog further to the north where it could avoid the conflict with the sewer.

Describe proposed alternate measure that provide adequate protection to public health and safety.

The segment of water pipe in conflict will be encased in CLSM.

EMAIL this form along with plans of proposed waiver request and additional supporting information to your regulator or dws.planreview@odhsoha.oregon.gov. If you are unable to send your documents electronically, please contact OHA before mailing them.

*Signature:



Date: 10/2/2025

Name: Mac Gifford

*Use Adobe Acrobat E-sign: <https://helpx.adobe.com/acrobat/using/signing-pdfs.html>

Continue to page 2.

800 NE Oregon St., Ste 640, Portland, OR 97232-2162

Voice: 971-673-0405 | Fax: 503-673-0694

All relay calls accepted | www.healthoregon.org/dws

Address: 1900 N Interstate Blvd, B320

City/State/Zip: Portland, OR 97227

Phone Number: 503-823-1507

Email Address: mac.gifford@portlandoregon.gov

☐ Comments:

☒ Attachments (describe):

Improvement Plans for NE 136th PI

OHA Use Only

Waiver ID: 2025-557

Entered into waiver database ☒

☒ Plan Review Coordinator's notes: Proposed encasement with CLSM is an appropriate remedy for the Zone 2 conflict.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

☒ Approved Comments (may be continued on page 3):

☐ Denied

Kari Salis

10/3/2025

Technical Services Unit or Regional Manager
OHA Drinking Water Services

Date

Waiver database updated ☒

OHA Use Only

Manager's Comments: