

Application for Waiver from Construction Standards for Public Water Systems

Water System Name	Portland Water Bureau	PWS ID	00657
Project or Facility	SE Grant St from 114 th to 117 th Ave	County	Multnomah
Need for waiver identified:	<input type="checkbox"/> Water System Survey	Date of Survey	
	<input type="checkbox"/> Plan Review # Exempt		

Construction standard requested to be waived: OAR 333-061-0050 (9)(b) water sewer separation

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. 680 ft of new water pipe will be installed in SE Grant. A short segment at the beginning will not have 5' of parallel horizontal separation from an existing sanitary sewer. The sewer is 7' at this location.

Describe why meeting the standard is highly burdensome or impractical. The new water main must connect to the existing water system and cannot be moved further south to avoid conflict with the stormwater catch basin and curb.

Describe proposed alternate measure that provide adequate protection to public health and safety. The proposed water pipe will be encased in CLSM from 0+13 to 0+28 where the pipe is within 5' horizontally from the sewer pipe.

Signature

12/8/2023

Date

Name Mac Gifford
 Address 1900 N Interstate Ave
 City/State/Zip Portland, OR 97227

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:
 Oregon Health Authority
 Drinking Water Services #640
 PO Box 14450
 Portland, OR 97293-0450

Telephone Number 503-823-1507

Comments:

Attachments: Improvement Plans

OHA Use Only

Waiver ID 466-2023

Entered into waiver database

Plan Review Coordinator's notes: Encasement with CLSM is an acceptable zone 2 conflict mitigation.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Kari Salis

12/18/23

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated