

Application for Waiver from Construction Standards for Public Water Systems

Water System Name	Portland Water Bureau	PWS ID	00657
Project or Facility	2877 SE 118 th Ave	County	Multnomah
Need for waiver identified:	<input type="checkbox"/> Water System Survey	Date of Survey	
	<input checked="" type="checkbox"/> Plan Review # Exempt		

Construction standard requested to be waived: OAR 333-061-0050 (9)(b) water sewer separation

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. Water and sewer services will be installed for a residential urban infill project, with very narrow utility access. The new water and new sewer services will only have 3' of parallel horizontal separation for the 13' between the mains and the property line. The sewer line is below the waterline, making it a Zone 2 conflict.

Describe why meeting the standard is highly burdensome or impractical. The utility access corridor is very narrow to access the flag lot. An existing utility pole prevents moving the water and sewer services any further apart.

Describe proposed alternate measure that provide adequate protection to public health and safety. The water service will be encased in CLSM.

11/27/2024
Date

Signature

Name Mac Gifford
Address 1900 N Interstate Ave
City/State/Zip Portland, OR 97227

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:
Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

Telephone Number 503-823-1507

Comments:

Attachments: Site Plan by BW Construction for SE 118th

OHA Use Only

Waiver ID 503-2024

Entered into waiver database

Plan Review Coordinator's notes: Mitigation appears to offer appropriate public health protection.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Kari Salis

12/3/2024

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated