



Public Health Division – Drinking Water Services
Kate Brown, Governor

Application for Waiver from Construction Standards for Public Water Systems

As Provided under OAR 333-061-0055, The Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

In accordance with the above, the Rickreall Water Association water system, PWS ID #41 00704, hereby requests the Oregon Health Authority to waive the construction standard OAR 333-061-0050 _____

The construction standard requested to be waived is for the following project: _____

well #1 Shop Well located at 1525 Independence Hwy
Independence, OR 97351

This waiver is necessary for the following reasons: the well was properly constructed according to construction standards when it was put on line - unable to purchase additional property from land owner

Proposed alternate measures to protect the health and welfare of the public in lieu of complying with the construction standards OAR 333-061-0050 will consist of: _____

Attach plans of proposed waiver request or additional supporting information and mail to:

Doris M. Rocha
Signature _____ Date _____
Print Name DORIS M. ROCHA
Address P.O. Box 44
Rickreall, OR 97371
Telephone # 503-623-2014

Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

☐ Plan review coordinator's notes on justification/mitigation: _____

☐ Comments: _____

☐ Attachments

Oregon Health Authority Action

After due consideration, the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

☐ Approved
☒ Denied

Kari Salis

Drinking Water Regional Manager Signature
Oregon Health Authority
Telephone # _____

2/3/20.
Date

*no well log or
evaluation
provided.
also mit rates ~ 8 ppm*