

Application for Waiver from Construction Standards for Public Water Systems

As Provided under OAR 333-061-0055, The Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

In accordance with the above, the Rickreall Water Association water system, PWS ID #41 00704, hereby requests the Oregon Health Authority to waive the construction standard OAR 333-061-0050 _____

The construction standard requested to be waived is for the following project: _____

well #2
Orchard well located at 1180 Independence Hwy
Independence, OR 97351

This waiver is necessary for the following reasons: the well was properly
constructed according to construction standards
when it was put on line - unable to purchase additional
Property from land owner

Proposed alternate measures to protect the health and welfare of the public in lieu of complying with the construction standards OAR 333-061-0050 will consist of: _____

Attach plans of proposed waiver request or additional supporting information and mail to:

Doris M. Rocha

Signature

Date

Print Name DORIS M. ROCHA

Address P.O. Box 44

Rickreall OR 97371

Telephone # 503 623-2016

Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

☐ Plan review coordinator's notes on justification/mitigation: _____

☐ Comments: _____

☐ Attachments

Oregon Health Authority Action

After due consideration, the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

☐ Approved

☒ Denied

*unconfined well,
sensitive aquifer,
high nitrate 7-8 ppm.*

Kari Salis

2/3/2020.

Drinking Water Regional Manager Signature

Date

Oregon Health Authority

Telephone # _____