

Application for Waiver from Construction Standards for Public Water Systems

| | | | |
|--|--|----------------|-------------|
| Water System Name | City of Keizer | PWS ID | 00744 |
| Project or Facility | Reitz Well | County | Marion |
| Need for waiver identified: | <input checked="" type="checkbox"/> Water System Survey | Date of Survey | 12/14/2023- |
| Performed by Engineer of Record (Edward Butts) | <input checked="" type="checkbox"/> Plan Review # 115-2022 | | |

Construction standard requested to be waived: OAR 333-061-0050 Construction Standards, Section 2 (General), Subsection A (Wells), Paragraphs B, C, E. Waiver requested under paragraph F stating: Except as in paragraph (2)(a)(A) and (2)(a)(E) of this rule, in those areas served by community gravity sanitary sewers, the area of ownership or control may be reduced to 50 feet

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. The 100' setback requirement not met in all directions due to inadequate space on site. New well drilled in 2023 has replaced a prior approved well that is now abandoned.

Describe why meeting the standard is highly burdensome or impractical. Space is not available on site to meet 100' setback in all directions, therefore, as per paragraph F a 50' setback is requested.

Describe proposed alternate measure that provide adequate protection to public health and safety. Well was drilled to a compensible depth to provide greater than 100' control to screen section.

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsoha.state.or.us; or
- Mail:
Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

Brooke Shattuck
Signature

3/13/2024
Date

Name Brooke Shattuck
Address 4454 71st Ave SE
City/State/Zip Salem, OR 97317
Telephone Number 503-580-8152

Comments:

Attachments:

OHA Use Only

Waiver ID 470-2024

Entered into waiver database

Plan Review Coordinator's notes: Well is properly constructed in a confined aquifer, which is an acceptable mitigation.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Kari Salis

3/13/2024

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated