

Application for Waiver from Construction Standards for Public Water Systems

Water System Name	Terrebonne Domestic Water District	PWS ID	00860
Project or Facility	Well #4/Sewer Line placement	County	Deschutes
Need for waiver identified:	<input type="checkbox"/> Water System Survey	Date of Survey	
	<input type="checkbox"/> Plan Review #		

Construction standard requested to be waived: OAR 333-061-0050 (2)(a)(E)

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. A low pressure sewer line is to be installed that will be located between 50 and 100 feet from Well #4 (source AD)

Describe why meeting the standard is highly burdensome or impractical. The location of the sewer main is a critical component of the proposed collection system network and is necessary for the system to function. Existing facilities and no alternative mainline routes provide the basis for this alignment.

Describe proposed alternate measure that provide adequate protection to public health and safety. Well is properly constructed in a confined aquifer.

	Feb 28,2024
Signature	Date

Name Carrie Gentry created waiver form
 Address based on submittal from Ryan
 Rudnick,PE at Parametrix
 City/State/Zip
 Telephone Number

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:
 Oregon Health Authority
 Drinking Water Services #640
 PO Box 14450
 Portland, OR 97293-0450

Comments:

Attachments:

OHA Use Only

Waiver ID 475-2024

Entered into waiver database

Plan Review Coordinator's notes: Well is properly constructed in a confined aquifer. Well is considered moderately sensitive. Geologist review indicated that additional analysis suggests that water from the well is not susceptible to the sewer line.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved

Comments: Note that sewer project hopes to resolve the nitrate issue in the area.

Denied

Kari Salis

4/16/2024

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated