

**Application for Waiver from Construction Standards for Public Water Systems**

Water System Name **Columbia Acres Water Assoc.** PWS ID **01148**  
Project or Facility **Well #2** County **Columbia**  
Need for waiver identified:  Water System Survey Date of Survey  
 Plan Review # **134-2002**

Construction standard requested to be waived: OAR 333-061-0050 (2)(a)(B) & (D)



As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. **Only owns & controls 80' radius around well.**

Describe why meeting the standard is highly burdensome or impractical. **Impossible to attain an easement or purchase land from neighbor to achieve the 100' radius of control around the well.**

Describe proposed alternate measure that provide adequate protection to public health and safety. **2019 well test data allowed a stronger well evaluation to show aquifer is protected.**

  
Signature  
  
Date

Signature

Date

Name **Robert Trotter**  
Address **POB 699**  
City/State/Zip **Newberg, OR 97129**  
Telephone Number **503.554.8333**

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email [dws.planreview@dhsosha.state.or.us](mailto:dws.planreview@dhsosha.state.or.us); or
- Mail:

Oregon Health Authority  
Drinking Water Services #640  
PO Box 14450  
Portland, OR 97293-0450

Comments:

Attachments:

**OHA Use Only**

Waiver ID **2023-456**

Entered into waiver database

Plan Review Coordinator’s notes: Well is properly constructed and based on well test data from 2019, the aquifer is presumed to be confined.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved    Comments:

Denied

*Kari Salis*

7/6/23

Drinking Water Regional Manager Signature  
Oregon Health Authority

Date

Waiver database updated