

Public Health Division - Drinking Water Services
Kate Brown, Governor



Application for Waiver from Construction Standards for Public Water Systems

As Provided under OAR 333-061-0055, *The Department may grant waivers from the construction standards prescribed by these rules:*

- (a) *When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and*
- (b) *When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and*
- (c) *When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.*

In accordance with the above, the Bradley State Wauside water system, PWS ID #41 91007, hereby requests the Oregon Health Authority to waive the construction standard OAR 333-061-0050 (2)(a)(E) sanitary hazards not allowed within 100 ft.

The construction standard requested to be waived is for the following project: RV Dump w/in 100 feet of well head.

This waiver is necessary for the following reasons: The host site location is pivotal to operations at the Bradley site. Per the Hydrogeologist the sanitary hazard location does not pose a risk to the well as it is unlikely to permeate deep enough to contaminate
Proposed alternate measures to protect the health and welfare of the public in lieu of complying with the construction standards OAR 333-061-0050 will consist of: Routine water aquifer quality sampling in accordance with OHA quarterly / Annual schedule as defined on the Drinking Water web profile for this system.

Attach plans of proposed waiver request or additional supporting information and mail to:

MS
 Signature _____ Date 10/14/24
 Print Name Michael Simonsen
 Address 100 Peter Iredale Rd.
Hammond, OR 97121
 Telephone # 503-861-3170 ex 27

Oregon Health Authority
 Drinking Water Services #640
 PO Box 14450
 Portland, OR 97293-0450

Plan review coordinator's notes on justification/mitigation: Based on location of RV dump relative to well head (less than 10'), the risk to public health appears to be high.

Comments: Waiver ID 501-2024

Attachments

Oregon Health Authority Action

After due consideration, the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved

Denied

Since the sewage dump pipe is 5 feet from well and goes underground, an impermeable surface or other alternate measure is not possible.

Kari Salis

10/30/2024

Drinking Water Regional Manager Signature

Date

Oregon Health Authority

Telephone # _____