

Application for Waiver from Construction Standards for Public Water Systems

Water System Name Stockmans Cafe/Eugene Livestock Auction PWS ID 41-93974
Project or Facility County Lane
Need for waiver identified: Water System Survey Date of Survey
 Plan Review #23-2023

Construction standard requested to be waived: OAR 333-061-0050 2(a)(E)

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. See 2nd page

Describe why meeting the standard is highly burdensome or impractical. See 2nd page

Describe proposed alternate measure that provide adequate protection to public health and safety. See 2nd page

Chloe Birky 9-7-2023
Signature Date

Name
Address
City/State/Zip
Telephone Number

Comments:
 Attachments: 1 page

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:
Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

OHA Use Only

Waiver ID 2023-458

Entered into waiver database

Plan Review Coordinator's notes: Well is properly constructed in a confined aquifer.

Neither well nor aquifer is considered highly sensitive to local land use practices.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Kari Salis

9/8/23

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated

The conflict with our well is that our existing well is located near a parking lot and livestock pen.

Meeting the standard is highly burdensome and impractical because it isn't possible to move the well, parking lot or livestock pen.

The proposed alternate measure is that this well is properly constructed in a confined aquifer.