

Application for Waiver from Construction Standards for Public Water Systems

Water System Name	Riverside RV	PWS ID	94601
Project or Facility	Well Conservation	County	Clackamas
Need for waiver identified:	<input checked="" type="checkbox"/> Water System Survey	Date of Survey	11/7/24
	<input type="checkbox"/> Plan Review #		

Construction standard requested to be waived: OAR 333-061-0050 2E

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. During the Santiary survey it was noted that there are several sewer lines including the main line that run within 50 feet of the well head.

Describe why meeting the standard is highly burdensome or impractical. Reconstruction of the sewerline would disturb the present structure of the sewerlines within the park. The system actively maintains a chlorination residual for disinfection. At this time there have not been any coliform positive results within the system in nearly 15 years.

Describe proposed alternate measure that provide adequate protection to public health and safety. To preserve the structure integrity of the existing sewer lines, the system would continue the ensure the established practices of restricting ground disturbance and maintaining the sewer lines, especially within the 50 ft of the wellhead.

_____	02/25/2025
Signature	Date

Name Jessica Perryman
Address 700 N College St

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:

Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

City/State/Zip Newberg, OR 97132
Telephone Number 503-554-8333 ext 107

☐ Comments:

☐ Attachments:

OHA Use Only

Waiver ID 525-2025

Entered into waiver database ☒

☐ Plan Review Coordinator's notes:

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

☐ Approved

☒ Denied

Comments: Well is highly sensitive to local fecal contaminant sources. No adequate alternate measure provided / available.



4/2/2025

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated ☒