

Application for Waiver from Construction Standards for Public Water Systems

Water System Name Paradis Vineyards PWS ID 95719
Project or Facility Well County Marion
Need for waiver identified: [] Water System Survey Date of Survey 10/2/23
[X] Plan Review # 132-2023

Construction standard requested to be waived: OAR 333-061-0050

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
(b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
(c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. - Vineyard and Chemical application operating within 100 feet of the well

Describe why meeting the standard is highly burdensome or impractical. Meeting this standard would require removal of vineyard within the radius which would be both impractical and counterintuitive to operation.

Describe proposed alternate measure that provide adequate protection to public health and safety. The proposed alternative is that the well is properly constructed within an contained aquifer

[Handwritten Signature]

1/3/24
Date

Name Tim Paraidis
Address 17627 Abiqua Rd Ne
City/State/Zip Silverton, Or 97381
Telephone Number 503-873-9463

Attach plans of proposed waiver request or additional supporting information and
• Email your regulator; or
• Email dws.planreview@dhsosha.state.or.us; or
• Mail:
Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

Comments:

Attachments:

OHA Use Only

Waiver ID 472-2024

Entered into waiver database

Plan Review Coordinator's notes: Well is properly constructed in a confined aquifer, which is an acceptable mitigation.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Kari Salis

April 1, 2024

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated