

Application for Waiver from Construction Standards for Public Water Systems

Water System Name Chehalem Valley Winery Tasting Room PWS ID 95731
 Project or Facility Chehalem Tasting Room County Yamhill
 Need for waiver identified: Water System Survey Date of Survey
 Plan Review # 28-2024

Construction standard requested to be waived: OAR 333-061-0050


As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. Owner desires to bury two ~1000 gallon propane tanks in close proximity to the new tasting room which also places the tanks within 50 feet of the new well.

Describe why meeting the standard is highly burdensome or impractical. Moving the tanks from the original location makes it more costly due to longer pipe runs, more chances of failure, and less conducive for ease of filling/refilling the tanks. The location shown in the attached sketch is optimal for constructability, cost-effectiveness, and maintenance.

Describe proposed alternate measure that provide adequate protection to public health and safety. Propane is not classified as a petroleum produce so therefore does not represent a risk to the well, therefore no public health safety risk.


Signature

04/19/24
Date

Name Ryan Thornton
Address PO Box 189
City/State/Zip Dayton, OR 97114

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email dws.planreview@dhsosha.state.or.us; or
- Mail:
Oregon Health Authority
Drinking Water Services #640
PO Box 14450
Portland, OR 97293-0450

Telephone Number 971-241-4871

Comments:

Attachments: Chehalem Tasting Room - Proposed Propane Tank Location.pdf

OHA Use Only

Waiver ID

Entered into waiver database

Plan Review Coordinator's notes: Well is properly constructed in a confined aquifer, which is an acceptable mitigation.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Kari Salis

April 23, 2024

Drinking Water Regional Manager Signature
Oregon Health Authority

Date

Waiver database updated