

**Application for Waiver from Construction Standards for Public Water Systems**

Water System Name	RAW Cider Company	PWS ID	41-95737
Project or Facility	RAW Cider Tasting Room	County	Yamhill
Need for waiver identified:	<input type="checkbox"/> Water System Survey	Date of Survey	
	<input checked="" type="checkbox"/> Plan Review # 45-2024		

Construction standard requested to be waived: OAR 333-061-0050 2(a)(D)

As provided under OAR 333-061-0055, the Department may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of the Department that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by the Department to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of the Department, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard. NE McDougall Rd roughly 50 ft away

Describe why meeting the standard is highly burdensome or impractical. The well was placed in the best and safest location on the property and the public road will not be moved.

Describe proposed alternate measure that provide adequate protection to public health and safety. The well was adequately constructed into a deep confined layer basalt aquifer and therefore, both the well and the aquifer have a low susceptibility to activities associated with the road.

*Levi Danielson*

	17JUN24
Signature	Date

Name Levi Danielson  
 Address 10670 SW Hall Blvd  
 City/State/Zip Portland, OR 97223  
 Telephone Number 5074599304

Attach plans of proposed waiver request or additional supporting information and

- Email your regulator; or
- Email [dws.planreview@dhsosha.state.or.us](mailto:dws.planreview@dhsosha.state.or.us); or
- Mail:  
 Oregon Health Authority  
 Drinking Water Services #640  
 PO Box 14450  
 Portland, OR 97293-0450

Comments:

Attachments:

**OHA Use Only**

Waiver ID 491-2024


Entered into waiver database

Plan Review Coordinator's notes: Well is properly constructed in a confined aquifer with low susceptibility, which is an acceptable mitigation.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved    Comments:

Denied



3.5.26

Drinking Water Regional Manager Signature  
Oregon Health Authority

Date

Waiver database updated