

Application for Waiver from Construction Standards for Public Water Systems

Revised March 2025

Water System Name: Boones Ferry Berry Farm

PWS ID: 4195749

Project or Facility: New Well

County: Marion

Need for waiver identified: Water System Survey

Date of Survey: 5/7/2025

Plan Review # 73-2022

Construction standard requested to be waived: OAR 333-061-0050 2(a)(E)

As provided under OAR 333-061-0055, OHA may grant waivers from the construction standards prescribed by these rules:

- (a) When it is demonstrated to the satisfaction of OHA that strict compliance with the rule would be highly burdensome or impractical due to special conditions or causes; and
- (b) When the public or private interest in the granting of the waiver is found by OHA to clearly outweigh the interest of the application of uniform rules; and
- (c) When alternate measures are provided which, in the opinion of OHA, will provide adequate protection to the health and safety of the public including the ability to produce water which does not exceed the maximum contaminant levels listed in rule 333-061-0030.

Describe situation that conflicts with the standard.

Gravel parking lot ~60 feet from well house.


Describe why meeting the standard is highly burdensome or impractical.

Due to limited space on the property, the parking lot cannot be relocated.

Describe proposed alternate measure that provide adequate protection to public health and safety.

Parking is only short term for agricultural worker's vehicles. Any long term parking can be relocated 100+ from the well. The well is properly constructed in a confined aquifer.

EMAIL this form along with plans of proposed waiver request and additional supporting information to your regulator or dws.planreview@odhsoha.oregon.gov. If you are unable to send your documents electronically, please contact OHA before mailing them.

*Signature: 	Date: 12-23-25
---	----------------

*Use Adobe Acrobat E-sign: <https://helpx.adobe.com/acrobat/using/signing-pdfs.html>

Name: Paul Snegirev

Address: 19602 Boones Ferry Rd NE

City/State/Zip: Hubbard, OR 97032

Phone Number: 971-260-7355

Email Address: customplanting@yahoo.com

Comments:

Attachments (describe):

OHA Use Only

Waiver ID: 587-2025

Entered into waiver database

Plan Review Coordinator's notes:

The well is properly constructed in a confined aquifer with low sensitivity.

After due consideration the above requested waiver from the construction standards of OAR 333-061-0050 is hereby:

Approved Comments:

Denied

Technical Services Unit or Regional Manager
OHA Drinking Water Services

3.3.26

Date

Waiver database updated