

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

May 2, 2016

Alan Mustain
City of Dundee
PO Box 220
Dundee, OR 97115

RE: Notice of failure to correct significant deficiencies at the City of Dundee, public water system ID# OR4100262

Dear Mr. Mustain,

This letter is to inform you the Oregon Health Authority has not been notified that significant deficiencies have been corrected by the November 19, 2015 due date at the City of Dundee water system. One of the deficiencies, that the sanitary seal and casing for one of the system's source water wells was not watertight, is considered a direct pathway for contamination to enter a water system and is a priority for correction.

The failure to correct the deficiencies by the original due date, following the June 15, 2015 sanitary survey is a violation of Oregon Administrative Rule (OAR) 333-061-0076(6) if, in fact, the deficiencies have not been corrected.

Please notify the Authority immediately if this deficiency or any other deficiencies from the June 15, 2015 sanitary survey have already been corrected. Otherwise, you must correct this deficiency within 30 days of the date of this notice and submit written verification of the date when the deficiency was corrected.

If you are unable to complete the correction within the specified time or if you have any questions about this notice, contact to Evan Hofeld at 971-673-0419. Your immediate attention to this matter is appreciated.

Respectfully,



Brad K. Daniels
Oregon Health Authority, Drinking Water Services

cc: Evan Hofeld, Oregon Health Authority, Drinking Water Services