



POLK COUNTY

COMMUNITY DEVELOPMENT

POLK COUNTY COURTHOUSE ★ DALLAS, OREGON 97338-3182
(503) 623-9237 ★ FAX (503) 623-6009

AUSTIN MCGUIGAN
DIRECTOR

October 18, 2016

Pioneer Park CO-OP
3945 Deepwood Ln NW
Salem, OR. 97304

RE: Compliance Schedule for Violations at the Pioneer Park CO-OP public water system

Dear Steve Albin (Water System Operator),

This letter is a follow-up to our conversation(s) regarding the timeframe for correction of the violations specified below at the Pioneer Park CO-OP. As we discussed, when a public water system has unresolved violations for more than 5 months, these violations must then be resolved within 90 days or the water system will be referred for formal enforcement.

The Pioneer Park CO-OP water system has the following violations that must be resolved within 90 days:

Violation #1: Source Fecal Contamination of the well; Well does not meet 4.0 log viral inactivation to remove source fecal contamination of the well.

Per our conversations, you have agreed to resolve the above violations according to the following compliance schedule:

- 1) Provide a Plan to correct the source water violation within 90 days; Prior discussions indicated that you were going to contact the Circuit Rider to help your water system resolve this issue and provide Polk County with a Correction Plan.

Failure to comply with the above compliance schedule may result in formal enforcement action which could include the assessment of civil penalties. If you have any questions or concerns, please call me at 503-623-9237.

Thank you for your cooperation.

Sincerely/Respectfully,


Jim Solvedt, REHS
Environmental Health Supervisor
Polk County

cc: Drinking Water Services Enforcement
Oregon Health Authority, Drinking Water Services