

February 15, 2015

Bruce Ogg
Eugene Mobile Village, LLC
dba Eugene Mobile Village
6208 N Camino De Corozal
Tucson, AZ 85704

RE: Notice of Non-Compliance regarding the Eugene Mobile Village Public Water System, PWS OR4101063

Mr Ogg:

Our records indicate that Eugene Mobile Village, LLC, owns and operates the Eugene Mobile Village water system located at 4750 Franklin Blvd., Eugene, Oregon. Therefore, Eugene Mobile Village, LLC, is a water supplier as defined in Oregon Revised Statute (ORS) 448.115(12) and Oregon Administrative Rule (OAR) 333-061-0020(207), and have specific responsibilities as defined in OAR 333-061-0025.

Eugene Mobile Village is a community public water system, which serves approximately 260 people and is subject to regulation under ORS 448.115 to 448.290 and OAR 333-061-0005 to 333-061-0272.

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of Eugene Mobile Village water system. This review has found that Eugene Mobile Village, LLC, is not in compliance with the following Oregon Administrative Rules, and is, therefore, not meeting its responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

DESCRIPTION OF RULE VIOLATIONS

- Violation No. 1: OAR 333-061-0036(2)(c) requires sampling for lead and copper for all community public water systems. DWS notified Stephen Robalik, the contact for the Eugene Mobile Village water system, by letter dated August 25, 2014 that lead

and copper results had not been submitted for the most recent monitoring period, January 1, 2011 to December 31, 2013.

DWS received four of the required five sample results for the most recent monitoring period for the Eugene Mobile Village water system on October 16, 2014. However, as of this notification, DWS has not received results for the fifth required sample, which is a violation of the rule if the fifth sample was, in fact, not collected.


ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, Eugene Mobile Village, LLC is required to complete the following actions relating to the Eugene Mobile Village water system:

- Compliance Action No. 1: Collect lead and copper samples in accordance with OAR 333-061-0036(2)(c) and report the sample results to DWS no later than **August 15, 2015**.
 - Lead and copper samples must be collected after **June 1, 2015**, which has been determined to be the start of the warmest part of the year. Samples collected before June 1, 2015 will not qualify for compliance or satisfy this compliance action.

Please contact Sarah Puls with Lane County Environmental Health at 541-682-3753 to discuss the compliance actions specified in this letter.

Respectfully,



Janet Brock
Compliance Specialist
OHA - Drinking Water Services

cc: Ernest Ogg, Registered Agent, Eugene Mobile Village, LLC
Sarah Puls, Lane County Environmental Health
Casey Lyon, Oregon Health Authority, Drinking Water Services