

August 10, 2015

Henrietta Knott
Bolder City Water System
PO Box 430
Jacksonville, OR 97530

RE: Violation of the Notice of Non-Compliance issued on March 17, 2015 and possible civil penalties.

On March 17, 2015, the Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) issued a Notice of Non-Compliance to you requiring corrective action to be completed at the Bolder City water system (PWS ID# OR4101154).

Specifically, the Notice required that significant deficiencies be corrected no later than June 1, 2015. One of the deficiencies, the failure to maintain a watertight roof or access hatch, is considered a direct pathway for contamination to enter the water system. June 1, 2015 has passed without correction of the significant deficiencies and you are now at risk of being assessed civil penalties in the amount of \$50 for every distinct rule violation and for every day the Bolder City water system is in violation of a rule (OAR 333-061-0090).

In the event that DWS assesses a civil penalty against you, you will be notified in writing and provided an opportunity for a hearing pursuant to the Oregon Administrative Procedures Act (ORS chapter 183).

To avoid being assessed civil penalties, you can immediately correct repair the water storage facility so that the roof or access hatch is water tight and verify your action with Brad Daniels at 971-673-0405.

Respectfully,



Brad K. Daniels
Enforcement Coordinator
Oregon Health Authority, Drinking Water Services

cc: Scott Curry, Oregon Health Authority, Drinking Water Services
Charlotte Knott, Bolder City Water System
Mike Obereigner, Jackson County Environmental Health