PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Kate Brown, Governor

Oregon Health Authority

800 NE Oregon St.
Portland, Oregon 97232-2162
Voice (971) 673-0405
FAX (971) 673-0694
TTY (971) 673-0372

March 22, 2016

Bobbie Bolden
Weiss Estates Water System Company, Inc.
88567 Weiss Estates Lane
Bandon, OR 97411

RE: Extension to the Notice of Violation and Administrative Order issued to Weiss Estates Water System Company, PWS OR4105581

On May 4, 2015, the Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (Authority) issued a Notice of Violation and Administrative Order (Order) to Weiss Estates Water System Company, Inc. (Company). The Order set forth actions to be completed by the Company to ensure concentrations of disinfectant byproducts in drinking water are below the maximum contaminant level (MCL) specified in OAR 333-061-0030(2)(b).

The Company has submitted a corrective action plan as required by the Order, but needs additional time to perform a tracer study and complete implementation of Compliance Action No. 2 as specified in the Order.

Based on the Company's progress to satisfy the terms of the Order, the Authority grants an extension of Compliance Action No. 2 and Compliance Action No. 3 in the Order as specified below.

TERMS OF THE EXTENSION

- Compliance Action No. 2: The Company must complete a tracer study and all corrective action at the Weiss Estates water system no later than August 31, 2016.

- Compliance Action No. 3: The Company must report the results of monitoring that demonstrates drinking water at the Weiss Estates water system has concentrations of haloacetic acids-five and total trihalomethanes below the MCL as specified in OAR 333-061-0030(2).

    - Monitoring must be conducted every 90 days for four consecutive calendar quarters according to OAR 333-061-0036(4) and beginning immediately after completing corrective action as specified in Compliance Action No. 2.

- The first round of monitoring must be conducted no later than September 30, 2016.
- Monitoring must be reported to the Authority no later than 10 days after the end of every calendar quarter and according to OAR 333-061-0040.

This extension applies only to the specific compliance actions identified above, and does not constitute a waiver, modification, or suspension of any other agreement activity, requirement, or term specified in the Order issued by the Authority on May 4, 2015, which remains in full force and effect.

Dated this 22nd day of MARCH, 2016

Jere High, ND
Interim Administrator, Center for Health Protection
Oregon Health Authority

cc: Betsy Parry, Oregon Health Authority, Drinking Water Services