

Terry Hinesly, President
Evergreen Meadows Water Improvement
District
PO Box 329
Shady Cove, OR 97539

RE: Extension to the Administrative Order issued on April 19, 2011 regarding the Evergreen Meadows Water Improvement District public water system, PWS OR4105946

The Evergreen Meadows Water Improvement District (Evergreen Meadows) water system is subject to the requirements of Oregon Revised Statutes (ORS), Chapter 448 and Oregon Administrative Rules (OAR), 333-061-0005 to 333-061-0290.

As you know, the Oregon Health Authority, Public Health Division, Office of Environmental Public Health, Drinking Water Program (Program) issued a Notice of Violation and Administrative Order (Order) on April 19, 2011 regarding the operation of the Evergreen Meadows water system.


You requested an extension to the deadlines specified in the Order because the District will rely upon financing through the Safe Drinking Water Revolving Loan Fund, and because that financing will not be available until late 2012. Based on the District's progress to meet the requirements in the Order, the Program hereby grants Evergreen Meadows an extension to the deadlines specified in the Order as prescribed below:

- Compliance Action No. 1: Evergreen Meadows must submit construction plans that clearly indicate how the Evergreen Meadows water system will be improved so that water users receive water that is below the MCL for arsenic. The plans must be submitted to the Program no later than September 30, 2012.
- Compliance Action No. 2: Evergreen Meadows must complete construction of any improvements to the Evergreen Meadows water system, related to Compliance Action No. 1 no later than December 31, 2012.
- Compliance Action No. 3: Evergreen Meadows must demonstrate no later than March 31, 2013 that the water produced by the Evergreen Meadows water system has concentrations of arsenic below the MCL, and that all users receive drinking water that consistently meets all applicable state and federal drinking water laws and rules.

This extension only applies to the specific compliance actions identified above, and it does not constitute a waiver, modification, or suspension of any other compliance actions, requirements, or information contained in the Order issued on April 19, 2011, which remain in full force and effect.

If you need the information in this letter in an alternate format, please contact Brad Daniels at 971-673-0405.

Dated this 9th day of November, 2011.



Gail R. Shibley, JD, Administrator
Office of Environmental Public Health

cc: Scott Curry, OHA-DWP
Mike Obereigner, Jackson County Health Department