



COMMUNITY HEALTH DIVISION

PUBLIC SERVICES BUILDING, # 367
2051 KAEN RD OREGON CITY, OR 97045

June 5, 2013

Tony Mann, Superintendent
Molalla River School District
PO Box 188
Molalla, OR 97038

RE: Exceedance of the Action Level for Lead at Rural Dell Elementary and requirement to issue Public Education Materials

Dear Mr. Mann:

~~Water samples collected at Rural Dell Elementary on June 5, 2012, February 26, 2013, and May 7, 2013 exceeded the action level for lead as specified by Oregon Administrative Rule (OAR) 333-061-0030(1).~~

When a public water system exceeds the action level for lead, regardless of the presence of corrosion control treatment, the owner or operator of that water system must publish public education materials as prescribed by OAR 333-061-0034(5) to all people served by the water system. Molalla River School District (the District) did not publish public education materials following the exceedances of the lead action level identified above.

The District will need to:

- Deliver public education materials as prescribed by OAR 333-061-0034(5) to all people served by the Rural Dell Elementary water system. The materials must also be distributed to every parent or legal guardian of a child enrolled at Rural Dell Elementary and be posted in a conspicuous location on school property such that school staff members and visitors to the school will see the materials.


The District must deliver the materials no later than **June 10, 2013**. A copy of the public education materials, as prescribed by OAR 333-061-0040(1)(g), must be submitted to the Oregon Health Authority within ten (10) days of delivering the materials.

- Collect samples for water quality parameters as prescribed by OAR 333-061-0036(2)(c)(F) and submit the sampling results to the Oregon Health Authority no later than July 10, 2013. It is my understanding that water quality parameters have been taken & results have been obtained.
- Please take a source lead & copper sample at the well head to rule out source contamination.

Report public education materials and water quality parameter sampling results to Pete Farrelly, OHA Drinking Water Services at peter.r.farrelly@state.or.us or fax them to 971-673-0694.

Please contact me at (503) 742-5367 with any questions you may have.

Respectfully,



Joel Ferguson, REHS
Clackamas County Environmental Health

cc: Brad Daniels, OHA Drinking Water Services
Pete Farrelly, OHA Drinking Water Services
Ric Dettwyler, Rural Dell Elementary