

February 23, 2016

Waiyen Yogi Yee  
USFS Fourmile Lake Campground  
2819 Dahlia St.  
Klamath Falls, OR 97601

Reminder of 2016 Start-up Requirements for the USFS Fourmile Lake Campground  
Water System, PWS OR4192829

Mr. Yee:

In July and September 2015, total coliform bacteria was confirmed in samples collected at your water system. This letter is a reminder to evaluate your water system for possible contamination and to collect samples to be analyzed for coliform bacteria before you open the park in June 2016. You can visit the OHA Drinking Water Services webpage, <http://public.health.oregon.gov/HealthyEnvironments/DrinkingWater/Operations/Pages/startup.aspx>, for more information about seasonal startup.

The presence of coliform bacteria in July and September 2015 constitutes an exceedance of the maximum contaminant level for coliform bacteria, which is specified in Oregon Administrative Rule (OAR) 333-061-0030(4). Owners and operators of public water systems are required to take action to make sure maximum contaminant levels are not exceeded.

When the water system opens to the public June 2016, please ensure a routine distribution sample is collected and analyzed for coliform bacteria and reported to the Oregon Health Authority by the 10<sup>th</sup> of the month following the sample collection date. This is required by OAR 333-061-0036(6). Also, as a reminder, effective April 1, 2016, revised total coliform rules go into effect which will require seasonal water systems to perform monthly distribution coliform sampling during the months of operation instead of quarterly sampling.


You can submit sampling results to DWS using one of the following methods:

1. Email the report to: [dwp.dmce@state.or.us](mailto:dwp.dmce@state.or.us)

2. Mail the report to: DMCE  
P.O. Box 14350,  
Portland, OR 97293-0350
3. Fax the report to (971) 673-0694

Thank you for your attention to this matter.

Sincerely,

A handwritten signature in cursive script that reads "Janet Brock".

Janet Brock  
Compliance Specialist

cc: Russ Kazmierczak, Oregon Health Authority, Drinking Water Services  
Delbert Bell, Klamath County Environmental Health