

November 24, 2014

Walter Boles
Walt's Mushroom Camp
69148 St Dennis Rd.
North Bend, OR 97459

RE: Notice of Non-Compliance regarding Walt's Mushroom Camp Public Water System

Mr. Boles,

Our records indicate that you own and operate Walt's Mushroom Camp (Walt's) water system located at 1079731 Hwy 97N, Chemult, Oregon. Therefore, you are a water supplier as defined in Oregon Revised Statute (ORS) [448.115\(12\)](#) and Oregon Administrative Rule (OAR) [333-061-0020\(207\)](#), and have specific responsibilities as defined in OAR [333-061-0025](#).

Walt's water system is a transient non-community public water system identified by public water system ID #41-95465 serving approximately 30 people and is subject to regulation under ORS 448.115 to 448.290 and OAR [333-061-0005](#).

The Oregon Health Authority, Public Health Division, Center for Health Protection, Drinking Water Services (DWS) has reviewed the operation of the Walt's water system. This review has found that you are not in compliance with the following Oregon administrative rules, and are therefore not meeting your responsibilities as a water supplier as prescribed by the Oregon Drinking Water Quality Act (ORS 448.115 to ORS 448.290) and rules.

Ramona Quinn with the Klamath County Health Department sent you a letter dated September 18, 2014 to inform you that you are in violation of the following rules and requested you complete the related compliance actions.

DESCRIPTION OF RULE VIOLATIONS

Walt's Mushroom Camp

Page 2

- Violation No. 1: [OAR 333-061-0036\(6\)](#) requires water suppliers to conduct sampling for coliform bacteria at all public water systems. These sampling results, as required by the rule, have not been reported to DWS as of the date of this notice. This constitutes a violation of OAR 333-061-0036(6).
- Violation No 2: OAR 333-061-0036(2)(d) requires water suppliers to conduct sampling for nitrate annually at all public water systems. These sampling results, as required by the rule, have not been reported to DWS as of the date of this notice. This constitutes a violation of OAR 333-061-0036(2)(d).
- Violation No. 3: OAR 333-061-0036(2)(a) requires, in part, water suppliers to collect a one-time sample for arsenic at all transient non-community water systems. These sampling results, as required by the rule, have not been reported to DWS as of the date of this notice. This constitutes a violation of OAR 333-061-0036(2)(a).
- Violation No. 4: OAR [333-051-0060\(1\)](#) requires that construction and installation plans be submitted by water suppliers and approved by DWS for all new water systems and major additions to existing water systems. As of the date of this notice, such plans have not been submitted to DWS, which constitutes a violation of OAR 333-061-0060(1).

ACTIONS REQUIRED TO ACHIEVE COMPLIANCE

Due to the rule violations identified above, you are required to complete the following actions relating to Walt's water system:

- Compliance Action No. 1: You must collect water samples for coliform bacteria at Walt's water system, and report the results to DWS as prescribed by OAR 333-061-0036(6) no later than September 30, 2015.
- Compliance Action No. 2: You must collect water samples for nitrate testing at Walt's water system, and report the results to DWS as prescribed by OAR 333-061-0036(2)(d) no later than September 30, 2015.

Walt's Mushroom Camp

Page 3

- Compliance Action No. 3: You must collect water samples for arsenic testing at Walt's water system, and report the results to DWS as prescribed by OAR 333-061-0036(2)(a) no later than September 30, 2015.
- Compliance Action No. 4: You must submit construction plans to DWS as prescribed by OAR 333-061-0060(1) no later than March 1, 2015.

Failure to complete the compliance actions described above puts you at risk of being assessed civil penalties in the amount of \$50 per day for each distinct rule violation and for every day Walt's water system is in violation of OAR [333-061-0090](#).

In the event that DWS assesses you with a civil penalty, you will be notified in writing and provided an opportunity for a hearing pursuant to the Oregon Administrative Procedures Act (ORS chapter 183).

To avoid being assessed civil penalties, you must immediately complete the actions specified in this letter.

Respectfully,



Janet Brock
Compliance Specialist
OHA - Drinking Water Services

cc: Ramona Quinn, Klamath County Environmental Health
Betsy Parry, OHA-DWP